



1201 North Bowser Road
 Richardson, Texas 75081
 (214) 346-6200
 Fax (214) 739-0095

Change Order No. 1

Mr. Mike Stone

This change order has been prepared to handle the current site conditions and the in-situ soil in the area between the mainlanes and frontage road. During the initial stages of the project, the in-situ material was tested and has a PI of 4. Lime stabilization is not effective for stabilizing this material due to the low PI. Since lime is no longer an option, here are two options for stabilizing this area. They are replacing the lime treated subgrade with cement stabilized base or cement stabilization. The most cost effective of the two is cement stabilization. It was agreed upon that the application rate of 7% cement would ensure proper stabilization for the area. The contractor has agreed to use the TxDOT average low bid to speed up the approval process and not delay construction.

The following items are being created:

0275-6001 CEMENT	50 TON @ \$174.92 = \$8,746.00
0275-6002 CEMENT TREAT (EXIST MATL) (6")	2909 SY @ \$4.00 = \$11,636.00
	TOTAL = \$20,382.00

The following items are being removed:

0260-6006 LIME TRT (EXST MATL) (6")	2909 SY @ \$ 5.00 = \$14,545.00
0260-6012 LIME (HYR, COM, OR QK)(SLRY) OR QK(DRY) 40 TON @ \$175.00 = 7,000.00	
	TOTAL = \$21,545.00

This change order will decrease the total contract price by \$1,163.00. This change adds 0 days to the contract.

Weston Ulbricht

 Weston Ulbricht
 2020.09.22
 14:59:03-05'00"

Project Manager
 mc² mainlanes

Signature

Date

Recommended
 Vincent M. Pena, PE



Project Manager
 Half Associates, Inc.

Signature

Date

9/22/2020

