

REVIEW BY FORT BEND COUNTY COMMISSIONERS COURT

On this 2 day of JUNE, 2009, before the Fort Bend Commissioners Court came on to be heard and reviewed the accompanying notice of CENTERPOINT ENTEX

Job Location NORTH FIRETHORNE

Dated 05/22/09 BOND NO. 22-022-417 Permit No. 83647

to make use of certain Fort Bend County property subject to, "A Revised Order Regulating the Laying, Construction, Maintenance, and Repair of Buried Cables, Conduits, and Pole Lines, In, Under, Across or Along Roads, Streets, Highways, and Drainage Ditches in Fort Bend County, Texas, Under the Jurisdiction of the Commissioners Court of Fort Bend County, Texas," as passed by the Commissioners Court of Fort Bend County, Texas, date the 3rd day of August, 1987, recorded in Volume _____ of the Minutes of the Commissioners Court of Fort Bend County, Texas, to the extent that such order is not inconsistent with Article 1436a, Vernon's Texas Civil Statues. Upon Motion of Commissioner Meyers, seconded by Commissioner Patterson, duly put and carried, it is ORDERED, ADJUGED AND DECREED that said notice of said above purpose is hereby acknowledged by the Commissioners Court of Fort Bend County, Texas, and that said notice be placed on record according to the regulation order thereof.

Notes:

- 1. Evidence of review by the Commissioners Court must be kept on the job site and failure to do so constitutes grounds for job shutdown.
- 2. Written notices are required:
 - a. 48 hours in advance of construction start up, and
 - b. When construction is completed and ready for final inspection

Mail notices to: Permit Administrator
Fort Bend County Engineering
P.O. Box 1449
Rosenberg, Texas 77471
281-633-7500

- 3. This permit expires one (1) year from date of permit if construction has not commenced.

By [Signature]
County Engineer

By N/A
Drainage District Engineer/Manager

Presented to Commissioners Court and approved.
Recorded in Volume 6-2-09
Minutes of Commissioners Court.

Clerk of Commissioners Court
By [Signature]
Deputy

NOTICE OF PROPOSED CABLE, CONDUIT AND / OR POLE LINE ACTIVITY
IN, UNDER, ACROSS OR ALONG ROADS, STREETS, HIGHWAYS AND DRAINAGE DITCHES
IN FORT BEND COUNTY

APPLICANT'S JOB NO. WO#50436474
 PERMIT NO. 83647 PCT. NO. 3
 BOND NO. 22-022-477

Formal notice is hereby given that CENTERPOINT ENTEX
 proposes to lay, construct, maintain and / or repair cable, conduit, and / or pole
 line, in, under, across, or along roads, streets, highways and drainage
 ditches in Fort Bend County, as follows:

In, Under, or Across Roads, and / or Drainage Ditches

Road or Ditch Name	Distance & Direction From Nearest Intersection	Length of Crossing	Type of Construction			
			Bored:	Jacked:	Driven:	Cased

Along Roads and / or Drainage Ditches

Road or Ditch Name	Distance & Direction From Nearest intersection	To	Distance
N. Firethorne Rd.	10' WW row of Arrowwood	1245' WW of Arrowwood	1245'

General Description

A 4" I.P. Plastic gas main on North Firethorne Rd. as shown on attached drawing. WO#50436474
 The location and description of the proposed installation and appurtenances is
 more fully shown on the attached detail drawings. The laying, construction,
 maintenance and / or repair of the proposed installation shall be subject to "A
 Revised Order Regulating the Laying, Construction, Maintenance and / or Repair
 of Cables, Conduits, and / or Pole Lines, In, Under, Across, or Along Roads,
 Streets, Highways and Drainage Ditches in Fort Bend County, Texas, Under the
 Jurisdiction of the Commissioners Court of Fort Bend County, Texas," as passed
 by Commissioners Court of Fort Bend County, Texas, dated the 3rd. day of
 August, 1987, recorded in Volume 639 of the Minutes of the Commissioners Court
 of Fort Bend County, Texas. **To Serve: Firethorne Sec.10 - Drawing. No. EB5-09313.**

Written notices are required: 1) 48 hours in advance of start of construction
 and 2) when construction is complete and ready for final inspection.

Mail To: Permit Administrator / Fort Bend County Engineering
 P. O. Box 1449, Rosenberg, Texas 77471

Violation of requirements shall constitute grounds for job shut down.

COMPANY NAME: CenterPoint Entex
 AGENT and / or OWNER

William A. Kuchar III *WAK*
 (Signature)


NAME & TITLE: William A. Kuchar III P.E.
Supervising Engineer
 (Please Print)

DATE: 5-6-09

ADDRESS: 1111 Louisiana - Ste. 1265B
 (Street / P.O. Box)

Houston Texas 77002
 City State Zip

TELEPHONE NO: (713) 207-4265 - Carter Hood
 (accessible 24 hrs/day, 7 days/week)



LEGEND AND NOTES
 EXIST. MAIN _____
 PROP. 4" P.L.A. 1.245"
 W.D. #500674
 PROP. LOC. TEST STA. Q
 PROP. 5# ANODE Q
 TEST PRESSURE 100 PSIG

CenterPoint Energy
 ENGINEERING
 DRAWING NO. EBS-09313

APPROACH FOR FIRETHORNE SEC-10 (#2210)

DESIGNED BY: C. MOON	DATE: 7/15/20	CONTRIBUTION:
ESTIMATED COST:	DATE NEEDED:	PURPOSE AND NECESSITY: TO SERVE AS APPROACH FOR FIRETHORNE SEC. 10 IN NATY.
RECOMMENDED BY:	DATE:	APPROVED BY: TREV KUCHAR
F:29970714 (D:29880712) KM:483 MLAMBERT:4257C Z: SZ:050 TC:504 S062:00131	DATE:	DATE 5-5-09

DESIGNED BY: C. MOON	DATE: 7/15/20	CONTRIBUTION:
ESTIMATED COST:	DATE NEEDED:	PURPOSE AND NECESSITY: TO SERVE AS APPROACH FOR FIRETHORNE SEC. 10 IN NATY.
RECOMMENDED BY:	DATE:	APPROVED BY: TREV KUCHAR
F:29970714 (D:29880712) KM:483 MLAMBERT:4257C Z: SZ:050 TC:504 S062:00131	DATE:	DATE 5-5-09