

11K

REVIEW BY FORT BEND COUNTY COMMISSIONERS COURT

On this 04 day of JANUARY, 2011, before the Fort Bend Commissioners Court came on to be heard and reviewed the accompanying notice of CENTERPOINT ENTEX

Job Location BELLAIRE BOULEVARD

Dated 12/27/10 BOND NO 22-022-417 Permit No. 83875
to make use of certain Fort Bend County property subject to, "A Revised Order Regulating the Laying, Construction, Maintenance, and Repair of Buried Cables, Conduits, and Pole Lines, In, Under, Across or Along Roads, Streets, Highways, and Drainage Ditches in Fort Bend County, Texas, Under the Jurisdiction of the Commissioners Court of Fort Bend County, Texas," as passed by the Commissioners Court of Fort Bend County, Texas, date the 3rd day of August, 1987, recorded in Volume _____ of the Minutes of the Commissioners Court of Fort Bend County, Texas, to the extent that such order is not inconsistent with Article 1436a, Vernon's Texas Civil Statutes. Upon Motion of Commissioner Prestage, seconded by Commissioner Morrison, duly put and carried, it is ORDERED, ADJUGED AND DECREED that said notice of said above purpose is hereby acknowledged by the Commissioners Court of Fort Bend County, Texas, and that said notice be placed on record according to the regulation order thereof.

Notes:

1. Evidence of review by the Commissioners Court must be kept on the job site and failure to do so constitutes grounds for job shutdown.
2. Written notices are required:
 - a. 48 hours in advance of construction start up, and
 - b. When construction is completed and ready for final inspection

Mail notices to: Permit Administrator
Fort Bend County Engineering
P.O. Box 1449
Rosenberg, Texas 77471
281-633-7500

3. This permit expires one (1) year from date of permit if construction has not commenced.

By Ronald Drachenberg
for County Engineer

By N/A
Drainage District Engineer/Manager

Presented to Commissioners Court
and approved.

Recorded in Volume 1-411
Minutes of Commissioners Court.

Clerk of Commissioners Court

By Sherry Fier
Deputy

NOTICE OF PROPOSED CABLE, CONDUIT AND / OR POLE LINE ACTIVITY
IN, UNDER, ACROSS OR ALONG ROADS, STREETS, HIGHWAYS AND DRAINAGE DITCHES
IN FORT BEND COUNTY

APPLICANT'S JOB NO. WO#55817763
PERMIT NO. 837015 PCT. NO. 3
BOND NO. 22-022-417

Formal notice is hereby given that CENTERPOINT ENTEX
proposes to lay, construct, maintain and / or repair cable, conduit, and / or pole
line, in, under, across, or along roads, streets, highways and drainage
ditches in Fort Bend County, as follows:

In, Under, or Across Roads, and / or Drainage Ditches

Road or Ditch Name	Distance & Direction From Nearest Intersection	Length of Crossing	Type of Construction			
			Bored:	Jacked:	Driven:	Cased
Bellaire Blvd.	At Parkway Lake Court	Shortside	X			

Along Roads and / or Drainage Ditches

Road or Ditch Name	Distance & Direction From Nearest intersection	To	Distance

General Description

A 2" IP Plastic natural gas main on shortside of Bellaire Blvd. as shown on attached drawing .

The location and description of the proposed installation and appurtenances is more fully shown on the attached detail drawings. The laying, construction, maintenance and / or repair of the proposed installation shall be subject to "A Revised Order Regulating the Laying, Construction, Maintenance and / or Repair of Cables, Conduits, and / or Pole Lines, In, Under, Across, or Along Roads, Streets, Highways and Drainage Ditches in Fort Bend County, Texas, Under the Jurisdiction of the Commissioners Court of Fort Bend County, Texas," as passed by Commissioners Court of Fort Bend County, Texas, dated the 3rd. day of August, 1987, recorded in Volume 639 of the Minutes of the Commissioners Court of Fort Bend County, Texas. **To Serve: 22341 Bellaire Blvd.**

Written notices are required: 1) 48 hours in advance of start of construction and 2) when construction is complete and ready for final inspection.

Mail To: Permit Administrator / Fort Bend County Engineering
P. O. Box 1449, Rosenberg, Texas 77471

Violation of requirements shall constitute grounds for job shut down.

COMPANY NAME: CenterPoint Entex
AGENT and / or OWNER

Cynthia Westcott
(Signature) 

NAME & TITLE: Cynthia L. Westcott
New Const. & System Imp. Mgr.
(Please Print)

DATE: 12/6/10


ADDRESS: 1111 Louisiana - Ste. 1265B
(Street / P.O. Box)

Houston Texas 77002
City State Zip
TELEPHONE NO: (713) 207-4265 - Carter Hood
(accessible 24 hrs/day, 7 days/week)



12/10/10 2:47:35 PM D:\Projects\2010\10102\10102.dwg

GAS STAKING	
JOB NO.:	BY:
ESMTS. DED. BY:	DATE:
MONUMENTATION FND.:	ESMT. DOCUMENTS:
ESMTS. NEEDED AT:	PLAT DIST. CHK -D-
NON-STD. STAKING: REASON:	



LEGEND AND NOTES	
EXIST. MAN	
PROP. 1" CTS SERVICE	65'
W.O. #581795	
PROP. 2" PL	66'
W.O. #581795	
PROP. 3" ANODE	9

ALTERNATE TO BE USED FOR TRACER WIRE SELECTION WHEN INSTALLING PLASTIC GAS LINES

- 1. USE 1/2" TRACER WIRE FOR ALL RESIDENTIAL
- 2. USE 1/2" TRACER WIRE FOR SHORT RUNS UP TO 100'
- 3. USE 3/4" TRACER WIRE FOR LONGER RUNS UP TO 200'
- 4. USE 1" TRACER WIRE FOR RUNS OVER 200'
- 5. USE 1" TRACER WIRE WITH ALL BONES LOCATIONS
- 6. USE 1" TRACER WIRE AS MANDATED FOR LARGE BONES CROSSINGS AND OTHER EXTRAORDINARY SITUATIONS
- 7. ALL BONES CROSSINGS AND OTHER EXTRAORDINARY SITUATIONS MUST BE APPROVED BY THE CITY ENGINEER PRIOR TO WORK.

TEST PRESSURE 100 PSIG

23042008 03/24/2008 104355.1 JAMES L. JAMES L. 52.078 12/03/2008 03/24/2008	
ESTIMATED COST:	713,250.4205
DATE:	12/10/2010
APPROVED BY:	DATE: 12/22/2010

22341 BELLAIRE
KIDS - R - KIDS

CenterPoint Energy
Power and Gas Engineering

EC5-10588