

REVIEW BY FORT BEND COUNTY COMMISSIONERS COURT

On this 14 day of JUNE, 2011, before the Fort Bend Commissioners Court came on to be heard and reviewed the accompanying notice of CENTERPOINT ENERGY ENTEX

Job Location MORGAN LANE

Dated 05/31/11 BOND NO 22-022-417 Permit No. 83961

to make use of certain Fort Bend County property subject to, "A Revised Order Regulating the Laying, Construction, Maintenance, and Repair of Buried Cables, Conduits, and Pole Lines, In, Under, Across or Along Roads, Streets, Highways, and Drainage Ditches in Fort Bend County, Texas, Under the Jurisdiction of the Commissioners Court of Fort Bend County, Texas," as passed by the Commissioners Court of Fort Bend County, Texas, date the 3rd day of August, 1987, recorded in Volume _____ of the Minutes of the Commissioners Court of Fort Bend County, Texas, to the extent that such order is not inconsistent with Article 1436a, Vernon's Texas Civil Statutes. Upon Motion of Commissioner Inyers, seconded by Commissioner Prestage, duly put and carried, it is ORDERED, ADJUGED AND DECREED that said notice of said above purpose is hereby acknowledged by the Commissioners Court of Fort Bend County, Texas, and that said notice be placed on record according to the regulation order thereof.

Notes:

1. Evidence of review by the Commissioners Court must be kept on the job site and failure to do so constitutes grounds for job shutdown.
2. Written notices are required:
 - a. 48 hours in advance of construction start up, and
 - b. When construction is completed and ready for final inspection

Mail notices to: Permit Administrator
Fort Bend County Engineering
P.O. Box 1449
Rosenberg, Texas 77471
281-633-7500

3. This permit expires one (1) year from date of permit if construction has not commenced.

By [Signature]
County Engineer

By N/A
Drainage District Engineer/Manager

Presented to Commissioners Court and approved.
Recorded in Volume 6-14-11
Minutes of Commissioners Court.

Clerk of Commissioners Court
By [Signature]
Deputy

COUNTY OF FORT BEND

Engineering Department

P.O. BOX 1449
Rosenberg, Texas 77471-1449

Johnny Ortega
Permit Administrator

1124 Blume Road
Phone: (281) 341-7500

PERMIT APPLICATION REVIEW FORM FOR CABLE, CONDUIT, AND POLE LINE ACTIVITY IN FORT BEND COUNTY

PERMIT NO. 083961

The following "Notice of Proposed Cable, Conduit, and/or Pole Line activity in Fort Bend County" and accompanying attachments have been reviewed and the notice conforms to appropriate regulations set by Commissioner's Court of Fort Bend County, Texas.

- (1) Complete Application Form.
- a. Name of road, street, and/or drainage ditch affected.
 - b. Vicinity map showing course of direction.
 - c. Plans and specifications.

- (2) Bond:
- District Attorney, approval when applicable.
- Perpetual bond currently posted.
No. 22-022-417
Amount \$50,000.00
- Performance bond submitted.
No. _____
Amount _____
- Cashier's Check.
No. _____
Amount _____

- (3) Verbal permission given for emergencies, to start construction before approved in Commissioner's Court.

Precinct Engineer Acknowledgment Date _____

Precinct Commissioner Acknowledgment Date _____

- (4) _____
Drainage District Approval when applicable

We have reviewed this project and agree it meets minimum requirements.



Johnny Ortega CFM/ Permit Administrator
(REVISED 5/30/08)

05/31/2011

Date

NOTICE OF PROPOSED CABLE, CONDUIT AND / OR POLE LINE ACTIVITY
IN, UNDER, ACROSS OR ALONG ROADS, STREETS, HIGHWAYS AND DRAINAGE DITCHES
IN FORT BEND COUNTY

APPLICANT'S JOB NO. 57966115
 PERMIT NO. 4396 PCT. NO. 1
 BOND NO. 22-022-411

Formal notice is hereby given that CENTERPOINT ENERGY ENTEX proposes to lay, construct, maintain and / or repair cable, conduit, and / or pole line, in, under, across, or along roads, streets, highways and drainage ditches in Fort Bend County, as follows:

In, Under, or Across Roads, and / or Drainage Ditches

Road or Ditch Name	Distance & Direction From Nearest Intersection	Length of Crossing	Type of Construction:			
			Bored	Jacked	Driven	Cased

Along Roads and / or Drainage Ditches

Road or Ditch Name	Distance & Direction From Nearest intersection	To	Distance
MORGAN LN	365' SS ST. HWY 36	680' SS ST. HWY 36	315'
BLK 13200			

General Description

The location and description of the proposed installation and appurtenances is more fully shown on the attached detail drawings. The laying, construction, maintenance and / or repair of the proposed installation shall be subject to "A Revised Order Regulating the Laying, Construction, Maintenance and / or Repair of Cables, Conduits, and / or Pole Lines, In, Under, Across, or Along Roads, Streets, Highways and Drainage Ditches in Fort Bend County, Texas, Under the Jurisdiction of the Commissioners Court of Fort Bend County, Texas," as passed by Commissioners Court of Fort Bend County, Texas, dated the 3rd. day of August, 1987, recorded in Volume 639 of the Minutes of the Commissioners Court of Fort Bend County, Texas.

Written notices are required: 1) 48 hours in advance of start of construction and 2) when construction is complete and ready for final inspection.

Mail To: Permit Administrator / Fort Bend County Engineering
 P. O. Box 1449, Rosenberg, Texas 77471

Violation of requirements shall constitute grounds for job shut down.

COMPANY NAME: CenterPoint Energy Entex
 AGENT and / or OWNER

SIGNATURE: Ravinder Duggal

NAME & TITLE RAVINDER DUGGAL
 Operations Engineer ADV. ENGINEERING COORDINATOR
 (Please Print)


DATE: May 19, 2011

ADDRESS: 1111 Louisiana -Rm 1265D
 (Street / P.O. Box)


Houston Texas 77002
 City State Zip

TELEPHONE NO: (713) 207-4601- Gloria Malone
 (accessible 24 hrs/day, 7 days/week)

Does project comply with Fort Bend County Outdoor Lighting Ordinance? Yes No



**FORT BEND COUNTY
PERMIT**



LOT NUMBER CHART						
MATERIAL NUMBER	SECTION	MAIN	FOOTAGE	PIPE CAT	Lot Number	FUSION METHOD
	A					EF BF SF SDL MECH
	B					EF BF SF SDL MECH
	C					EF BF SF SDL MECH
	D					EF BF SF SDL MECH
	E					EF BF SF SDL MECH
	F					EF BF SF SDL MECH
	G					EF BF SF SDL MECH
	ALL					EF BF SF SDL MECH

GAS STAKING

JOB NO: _____ BY: _____ DATE: _____

ESMTS. DED. BY: _____ ESMT. DOCUMENTS: _____

MONUMENTATION FND.: _____ PLAT DIST. CHK.=D: _____

ESMTS. NEEDED AT: _____

NON-STD. STAKING: _____ REASON: _____

LEGEND AND NOTES

EXIST. MAIN 315"

PROP. 2" P.L.A. 315"

W.O. #57965115

PROP. 5# ANODE **Q**

CRITERIA TO BE USED FOR TRACER WIRE SELECTION WHEN INSTALLING PLASTIC GAS LINES

- USE #14 TRACER WIRE FOR ALL RESIDENTIAL SERVICE LINES.
- USE #14 TRACER WIRE FOR SIGHT BORES UP TO 300' AND ALL OTHER NON-BORE INSTALLATIONS.
- USE #10 TRACER WIRE WITH ALL BORES LONGER THAN 300'.
- USE #8 TRACER WIRE AS NEEDED FOR LARGE BAVOU CROSSINGS AND OTHER EXTRAORDINARY SITUATIONS AND COMPLEX BORES.

INSPECTOR APPROVAL REQUIRED PRIOR TO WORK.

TEST PRESSURE 100 PSIG

DESIGNED BY: **BAWNER DIGGAL** (13-501-461)

ESTIMATED COST: _____ CONTRIBUTION: _____

DATE NEEDED: _____

LARGE AND NECESSITY TO SERVE ONE RES. CUSTOMER IN NEBUVILLE, FORT BEND COUNTY.

RECOMMENDED BY: _____ DATE: _____

APPROVED BY: _____ DATE: _____

13220 MORGAN LN

CenterPoint Energy

DESIGN BY: BECKY PEREZ

DATE: 05/17/2011

SCALE: 1"=60'

SHEET: _____

DWG No: **EB5-11311**

Texas Region - Houston Gas Engineering