

REVIEW BY FORT BEND COUNTY COMMISSIONERS COURT

On this 13 day of DECEMBER, 2011, before the Fort Bend Commissioners Court came on to be heard and reviewed the accompanying notice of CENTERPOINT ENTEX

Job Location DEL WEBB BOULEVARD

Dated 12/05/11 BOND NO. 22-022-417 Permit No. 84077

to make use of certain Fort Bend County property subject to, "A Revised Order Regulating the Laying, Construction, Maintenance, and Repair of Buried Cables, Conduits, and Pole Lines, In, Under, Across or Along Roads, Streets, Highways, and Drainage Ditches in Fort Bend County, Texas, Under the Jurisdiction of the Commissioners Court of Fort Bend County, Texas," as passed by the Commissioners Court of Fort Bend County, Texas, date the 3rd day of August, 1987, recorded in Volume _____ of the Minutes of the Commissioners Court of Fort Bend County, Texas, to the extent that such order is not inconsistent with Article 1436a, Vernon's Texas Civil Statues. Upon Motion of Commissioner Meyers, seconded by Commissioner Patterson, duly put and carried, it is ORDERED, ADJUGED AND DECREED that said notice of said above purpose is hereby acknowledged by the Commissioners Court of Fort Bend County, Texas, and that said notice be placed on record according to the regulation order thereof.

Notes:

1. Evidence of review by the Commissioners Court must be kept on the job site and failure to do so constitutes grounds for job shutdown.
2. Written notices are required:
 - a. 48 hours in advance of construction start up, and
 - b. When construction is completed and ready for final inspection

Mail notices to: Permit Administrator
Fort Bend County Engineering
P.O. Box 1449
Rosenberg, Texas 77471
281-633-7500

3. This permit expires one (1) year from date of permit if construction has not commenced.

By [Signature]
County Engineer

By N/A
Drainage District Engineer/Manager

Presented to Commissioners Court and approved.
Recorded in Volume 12-13-11
Minutes of Commissioners Court.

Clerk of Commissioners Court
By [Signature]
Deputy

NOTICE OF PROPOSED CABLE, CONDUIT AND / OR POLE LINE ACTIVITY
IN, UNDER, ACROSS OR ALONG ROADS, STREETS, HIGHWAYS AND DRAINAGE DITCHES
IN FORT BEND COUNTY

APPLICANT'S JOB NO. WO#59998159
 PERMIT NO. 84077 PCT. NO. 1
 BOND NO. 22-022-417

Formal notice is hereby given that CENTERPOINT ENTEX proposes to lay, construct, maintain and / or repair cable, conduit, and / or pole line, in, under, across, or along roads, streets, highways and drainage ditches in Fort Bend County, as follows:

In, Under, or Across Roads, and / or Drainage Ditches

Road or Ditch Name	Distance & Direction From Nearest Intersection	Length of Crossing	Type of Construction			
			Bored:	Jacked:	Driven:	Cased

Along Roads and / or Drainage Ditches

Road or Ditch Name	Distance & Direction From Nearest intersection	To	Distance
Del Webb Blvd between River Fern Dr & Cone Flower Dr	3' North of South property line of River Fern Dr 3' west of east ROW Del Webb at River Fern Dr.	1250' along 3' west of east ROW of Del Webb. End location 5' north of south Cone flower Dr.	1250'

General Description

A 6" IP plastic natural gas main along Del Webb Blvd between River Fern Dr and Cone Flower Dr as shown on attached drawing.

The location and description of the proposed installation and appurtenances is more fully shown on the attached detail drawings. The laying, construction, maintenance and / or repair of the proposed installation shall be subject to "A Revised Order Regulating the Laying, Construction, Maintenance and / or Repair of Cables, Conduits, and / or Pole Lines, In, Under, Across, or Along Roads, Streets, Highways and Drainage Ditches in Fort Bend County, Texas, Under the Jurisdiction of the Commissioners Court of Fort Bend County, Texas," as passed by Commissioners Court of Fort Bend County, Texas, dated the 3rd. day of August, 1987, recorded in Volume 639 of the Minutes of the Commissioners Court of Fort Bend County, Texas. **To serve: several Cinco Ranch S/D.**

Written notices are required: 1) 48 hours in advance of start of construction and 2) when construction is complete and ready for final inspection.

Mail To: Permit Administrator / Fort Bend County Engineering
P. O. Box 1449, Rosenberg, Texas 77471

Violation of requirements shall constitute grounds for job shut down.

COMPANY NAME: CenterPoint Entex
AGENT and / or OWNER
Anjum Pervaiz
(Signature)

NAME & TITLE: Anjum Pervaiz
Advanced Engineering Coordinator
(Please Print)

DATE: November 23th 2011

ADDRESS: 1111 Louisiana – Ste. 1264 D
(Street / P.O. Box)
Houston Texas 77002
City State Zip

TELEPHONE NO: (713) 207-4619– Anjum Pervaiz
(Accessible 24 hrs/day, 7 days/week)

LOT NUMBER CHART

Material Number	Section	Main	Footage	Pipe Cat	Lot Number	Fusion Method
	A					EF BF SF SDL MECH
	B					EF BF SF SDL MECH
	C					EF BF SF SDL MECH
	D					EF BF SF SDL MECH
	E					EF BF SF SDL MECH
	F					EF BF SF SDL MECH
	G					EF BF SF SDL MECH
	ALL					EF BF SF SDL MECH



FACET: P3033042
 WOP 55081152_P
 OP MAP: 03240540
 NS: 805M
 LAMBERT: 444804
 TC: UNK
 SC: 801
 SOQ: 07801

LEGEND:
 EXIST. MAIN
 PROP. 6" PL. GAS MAIN
 WOP 55081152 1287

GAS STAKING

JOB NO: _____ BY: _____ DATE: _____
 ESMTS. DED. BY: _____ ESMT. DOCUMENTS: _____
 MONUMENTATION FND.: _____ PLAT DIST. CHK=D: _____
 ESMTS. NEEDED AT: _____
 NON-STD. STAKING: _____ REASON: _____

PROP. 3/4 ANODE

ELECTRIC

- ELECTRIC ROUTE
- ELECTRIC PEDESTAL
- ELECTRIC PAD MOUNTED TRANSFORMER
- ELECTRIC STREET LIGHT
- ELECTRIC PULL HOLE
- CABLE
- CABLE PEDESTAL
- CABLE ROUTE
- TELECO
- SA BOX
- TELECO PEDESTAL
- TELECO ROUTE
- TELECO SPUR PIT

GENERAL NOTES:
 1- All streets are 67 R.O.W. unless otherwise noted.
 2- One meter and its divided 1/2 inch Trench Location.
 Refer to SA-9228, SA-9229 & SA-9234.
 3-CRITERIA TO BE USED FOR TRACER WIRE SELECTION WHEN INSTALLING PLASTIC GAS LINES
 A-USE #14 TRACER WIRE FOR ALL RESIDENTIAL SERVICE LINES.
 B-USE #14 TRACER WIRE FOR SHORT BORES UP TO 300' AND ALL OTHER NON-SHORE INSTALLATIONS.
 C-USE #10 TRACER WIRE WITH ALL BORES LONGER THAN 300'.
 D-USE #8 TRACER WIRE AS NEEDED FOR LARGE BATCH CROSSINGS AND OTHER EXTRAORDINARY SITUATIONS AND COMPLEX BORES. INSPECTOR APPROVAL REQUIRED PRIOR TO WORK.
 4-TEST PRESSURE 100 PSIG

APPROACH FOR DEL WEBB SECTION 5 JTP #2771

PURPOSE:
 CONSTRUCTION TO PROVIDE SERVICE TO 70 LOTS
 DESIGNER: ANJUM PERVAZ
 PHONE: 715-907-4819
 DRAWN BY: STEVE GIBSON BECKY PEREZ
 DESIGN DATE: 11/10/2011 11/16/2011

JOINT TRENCH DESIGN

RECOMMENDED BY:
 DATE:
 APPROVED BY: CANDY WESTCOTT
 DATE: 11/17/2011

SCALE: 1" = 80'
 SHEET: 1 OF 1
 "TO BE DIGITIZED DESIGNER EXPRESS"

