

REVIEW BY FORT BEND COUNTY COMMISSIONERS COURT

On this 12 day of JUNE, 20 12, before the Fort Bend Commissioners Court came on to be heard and reviewed the accompanying notice of CENTERPOINT ENTEX

Job Location GREENBUSCH ROAD

Dated 6/01/12 Bond No. 22-022-417, Permit No. 84159 to make use of certain Fort Bend County property subject to, "A Revised Order Regulating the Laying, Construction, Maintenance, and Repair of Buried Cables, Conduits, and Pole Lines, In, Under, Across or Along Roads, Streets, Highways, and Drainage Ditches in Fort Bend County, Texas, Under the Jurisdiction of the Commissioners Court of Fort Bend County, Texas," as passed by the Commissioners Court of Fort Bend County, Texas, date the 3rd day of August, 1987, recorded in Volume _____ of the Minutes of the Commissioners Court of Fort Bend County, Texas, to the extent that such order is not inconsistent with Article 1436a, Vernon's Texas Civil Statues. Upon Motion of Commissioner Meurers, seconded by Commissioner Patterson, duly put and carried, it is ORDERED, ADJUGED AND DECREED that said notice of said above purpose is hereby acknowledged by the Commissioners Court of Fort Bend County, Texas, and that said notice be placed on record according to the regulation order thereof.

Notes:

1. Evidence of review by the Commissioners Court must be kept on the job site and failure to do so constitutes grounds for job shutdown.
2. Written notices are required:
 - a. 48 hours in advance of construction start up, and
 - b. When construction is completed and ready for final inspection

Mail notices to: Permit Administrator
Fort Bend County Engineering
P.O. Box 1449
Rosenberg, Texas 77471
281-633-7500

3. This permit expires one (1) year from date of permit if construction has not commenced.

By [Signature]
County Engineer

By _____
Drainage District Engineer/Manager

Presented to Commissioners Court and approved.
Recorded in Volume 6-12-12
Minutes of Commissioners Court.

Clerk of Commissioners Court
By [Signature]
Deputy

NOTICE OF PROPOSED CABLE, CONDUIT AND / OR POLE LINE ACTIVITY
IN, UNDER, ACROSS OR ALONG ROADS, STREETS, HIGHWAYS AND DRAINAGE DITCHES
IN FORT BEND COUNTY

APPLICANT'S JOB NO. WO #61947886
 PERMIT NO. 84159 PCT. NO. 3
 BOND NO. 22-022-411

Formal notice is hereby given that CENTERPOINT ENTEX proposes to lay, construct, maintain and / or repair cable, conduit, and / or pole line, in, under, across, or along roads, streets, highways and drainage ditches in Fort Bend County, as follows:

In, Under, or Across Roads, and / or Drainage Ditches

Road or Ditch Name	Distance & Direction From Nearest Intersection	Length of Crossing	Type of Construction			
			Bored:	Jacked:	Driven:	Cased
Greenbusch Rd	810'+/- WW of Cherry Ranch	80'	yes			
Blk 3500	Dr					

Along Roads and / or Drainage Ditches

Road or Ditch Name	Distance & Direction From Nearest intersection	To	Distance

General Description

A 6" IP plastic natural gas main along Del Webb Blvd between River Fern Dr and Cone Flower Dr as shown on attached drawing.

The location and description of the proposed installation and appurtenances is more fully shown on the attached detail drawings. The laying, construction, maintenance and / or repair of the proposed installation shall be subject to "A Revised Order Regulating the Laying, Construction, Maintenance and / or Repair of Cables, Conduits, and / or Pole Lines, In, Under, Across, or Along Roads, Streets, Highways and Drainage Ditches in Fort Bend County, Texas, Under the Jurisdiction of the Commissioners Court of Fort Bend County, Texas," as passed by Commissioners Court of Fort Bend County, Texas, dated the 3rd. day of August, 1987, recorded in Volume 639 of the Minutes of the Commissioners Court of Fort Bend County, Texas.

To serve: 3510 GREENBUSCH RD (SWIM ACCADEMY-COMMERCIAL CUSTOMER)

Written notices are required: 1) 48 hours in advance of start of construction and 2) when construction is complete and ready for final inspection.

Mail To: Permit Administrator / Fort Bend County Engineering
P. O. Box 1449, Rosenberg, Texas 77471

Violation of requirements shall constitute grounds for job shut down.

COMPANY NAME: CenterPoint Entex
AGENT and / or OWNER
Ravinder Duggal
(Signature)


NAME & TITLE: RAVINDER DUGGAL
Advanced Engineering Coordinator
(Please Print)

DATE: May 17, 2012


ADDRESS: 1111 Louisiana - Ste. 1265 D
(Street / P.O. Box)
Houston Texas 77002
City State Zip

TELEPHONE NO: (713) 207-4621
(Accessible 24 hrs/day, 7 days/week)

**FOR QUESTIONS CONTACT
ELDON EILISTON @ 713-962-2945**



FORT BEND COUNTY PERMIT



**CHERRY RANCH DR
(ROW 100')**

GREENBUSCH RD (ROW 80')

LOT NUMBER CHART

Material Number	Section	Main	Footage	Pipe Cal.	Lot Number	EF	BF	SF	SDL	MECH
	A									
	B									
	C									
	D									
	E									
	F									
	G									
	ALL									



PROJECT WO# 61947886

FACET F30120708

OP MAP 030120704

KM 484R

LAMBERT 4356B3

4356A4

4356C2

TC 050

SZ 503

SOG 078

00151

LEGEND:

EXIST. MAIN _____

PROP. 1" CTS SVC. 190'

WO #61947886

GENERAL NOTES:

- CRITERIA TO BE USED FOR TRACER WIRE SELECTION WHEN INSTALLING PLASTIC GAS LINES:
 - A- USE #14 TRACER WIRE FOR ALL RESIDENTIAL SERVICE LINES.
 - B- USE #14 TRACER WIRE FOR SHORT BORES UP TO 300' AND ALL OTHER NON-BORE INSTALLATIONS.
 - C- USE #10 TRACER WIRE WITH ALL BORES LONGER THAN 300'.
 - D- USE #8 TRACER WIRE AS NEEDED FOR LARGE BAYOU CROSSINGS AND OTHER EXTRAORDINARY SITUATIONS AND COMPLEX BORES. INSPECTOR APPROVAL REQUIRED PRIOR TO WORK.
- TEST PRESSURE 100 PSIG

NOTIFICATION #1402602117

**3510 GREENBUSCH RD
(SWIM ACCADEMY)**

PURPOSE:
TO SERVE ONE CUSTOMER IN KATY,
FORT BEND COUNTY.

DESIGNER: RAVINDER DUGGAL
PHONE#: 713-207-4821
DRAWN BY: Becky Perez
DESIGN DATE: 5/16/2012

ESTIMATED COST:
CONTRIBUTION:
DATE NEEDED:

RECOMMENDED BY: RAVINDER DUGGAL
DATE: 05/17/2012

APPROVED BY:
DATE:

SCALE: 1" = 150'
SHEET: 1 OF 1