

149

REVIEW BY FORT BEND COUNTY COMMISSIONERS COURT

On this 25 day of JUNE, 2013, Commissioners Court
came on to be heard and reviewed the accompanying notice
of CENTERPOINT ENTEX

Job Location SPRING GREEN BOULEVARD, MORGAN PARKWAY

Dated 06/07/13 Bond No. 22-022-417, Permit No. 84374
to make use of certain Fort Bend County property subject to, "A Revised Order
Regulating the Laying, Construction, Maintenance, and Repair of Buried Cables,
Conduits, and Pole Lines, In, Under, Across or Along Roads, Streets, Highways, and
Drainage Ditches in Fort Bend County, Texas, Under the Jurisdiction of the
Commissioners Court of Fort Bend County, Texas," as passed by the Commissioners
Court of Fort Bend County, Texas, date the 3rd day of August, 1987, recorded in
Volume _____ of the Minutes of the Commissioners Court of Fort Bend County,
Texas, to the extent that such order is not inconsistent with Article 1436a, Vernon's
Texas Civil Statutes. Upon Motion of Commissioner Meyers, seconded
by Commissioner Morrison, duly put and carried, it is ORDERED,
ADJUGED AND DECREED that said notice of said above purpose is hereby
acknowledged by the Commissioners Court of Fort Bend County, Texas, and that said
notice be placed on record according to the regulation order thereof.

Notes:

1. Evidence of review by the Commissioners Court must be kept on the job site
and failure to do so constitutes grounds for job shutdown.
2. Written notices are required:
 - a. 48 hours in advance of construction start up, and
 - b. When construction is completed and ready for final inspection

Mail notices to: Permit Administrator
Fort Bend County Engineering
P.O. Box 1449
Rosenberg, Texas 77471
281-633-7500

3. This permit expires one (1) year from date of permit if construction has not
commenced.

By [Signature]
County Engineer

By _____
Drainage District Engineer/Manager

Presented to Commissioners Court
and approved.

Recorded in Volume 625-13
Minutes of Commissioners Court.

Clerk of Commissioners Court
By [Signature]
Deputy

COUNTY OF FORT BEND

Engineering Department

P.O. BOX 1449
Rosenberg, Texas 77471-1449

Johnny Ortega
Permit Administrator

1124 Blume Road
Phone: (281) 341-7500

PERMIT APPLICATION REVIEW FORM FOR CABLE, CONDUIT, AND POLE LINE ACTIVITY IN FORT BEND COUNTY

PERMIT NO. 004374

The following "Notice of Proposed Cable, Conduit, and/or Pole Line activity in Fort Bend County" and accompanying attachments have been reviewed and the notice conforms to appropriate regulations set by Commissioner's Court of Fort Bend County, Texas.

- X (1) Complete Application Form.
- X a. Name of road, street, and/or drainage ditch affected.
- X b. Vicinity map showing course of direction.
- X c. Plans and specifications.
- X (2) Bond:
- _____ District Attorney, approval when applicable.
- X Perpetual bond currently posted.
- No. 22-022-417
- Amount \$50,000.00
- _____ Performance bond submitted.
- No. _____
- Amount _____
- _____ Cashier's Check.
- No. _____
- Amount _____
- _____ (3) Verbal permission given for emergencies, to start construction before approved in Commissioner's Court.
- _____ Precinct Engineer Acknowledgment _____ Date
- _____ Precinct Commissioner Acknowledgment _____ Date
- _____ (4) _____
- _____ Drainage District Approval when applicable

We have reviewed this project and agree it meets minimum requirements.


Johnny Ortega CFM/Permit Administrator
(REVISED 5/30/08)

06/07/2013
Date

NOTICE OF PROPOSED CABLE, CONDUIT AND / OR POLE LINE ACTIVITY
IN, UNDER, ACROSS OR ALONG ROADS, STREETS, HIGHWAYS AND DRAINAGE DITCHES
IN FORT BEND COUNTY

APPLICANT'S JOB NO. WO#65699612
PERMIT NO. 84374 PCT. NO. 3
BOND NO. 22-022-417

Formal notice is hereby given that CENTERPOINT ENTEX
proposes to lay, construct, maintain and / or repair cable, conduit, and / or pole
line, in, under, across, or along roads, streets, highways and drainage
ditches in Fort Bend County, as follows:

In, Under, or Across Roads, and / or Drainage Ditches

Road or Ditch Name	Distance & Direction From Nearest Intersection	Length of Crossing	Type of Construction Bored: Jacked: Driven: Cased			

Along Roads and / or Drainage Ditches

Road or Ditch Name	Distance & Direction From Nearest intersection	To	Distance
Spring Green BLVD	338' S Of Morgan PKWY	Morgan PKWY	338'
Morgan PKWY	730' E of Spring Green BLVD		780'

General Description

Install 4" IP plastic pipe along Spring Green BLVD Rd and Morgan PKWY, heading North 338' on
Spring Green BLVD to the intersection of Spring Green BLVD and Morgan PKWY, head East 730',
tying into the existing 4" IP plastic main to create a feed to new customers.

The location and description of the proposed installation and appurtenances is
more fully shown on the attached detail drawings. The laying, construction,
maintenance and / or repair of the proposed installation shall be subject to "A
Revised Order Regulating the Laying, Construction, Maintenance and / or Repair
of Cables, Conduits, and / or Pole Lines, In, Under, Across, or Along Roads,
Streets, Highways and Drainage Ditches in Fort Bend County, Texas, Under the
Jurisdiction of the Commissioners Court of Fort Bend County, Texas," as passed
by Commissioners Court of Fort Bend County, Texas, dated the 3rd. day of
August, 1987, recorded in Volume 639 of the Minutes of the Commissioners Court
of Fort Bend County, Texas. **To Serve: The Reserve at Katy neighborhoods.**

Written notices are required: 1) 48 hours in advance of start of construction
and 2) when construction is complete and ready for final inspection.

Mail To: Permit Administrator / Fort Bend County Engineering
P. O. Box 1449, Rosenberg, Texas 77471

Violation of requirements shall constitute grounds for job shut down.

COMPANY NAME: CenterPoint Entex
AGENT and / or OWNER

Sam Cook
(Signature)

NAME & TITLE: Sam Cook
Engineering Technician I
(Please Print)

DATE: June 7th, 2013

ADDRESS: 1111 Louisiana – Ste. 1248 B
(Street / P.O. Box)

Houston Texas 77002
City State Zip
TELEPHONE NO: (713) 207-5644– Sam Cook
(Accessible 24 hrs/day, 7 days/week)

LEGEND:

WIST. MAIN

PROP. 4" IP PILA 1.078'

04/65699412

PROP. 58 ANODE

PROP. TEST STATION

PROP. LOCAT. TEST STATION

GENERAL NOTES

CRITERIA TO BE USED FOR TRACER WIRE SELECTION WHEN INSTALLING USE #1 TRACER WIRE FOR ALL RESIDENTIAL SERVICE LINES.

USE #1 TRACER WIRE FOR ALL OTHER NON-HOME INSTALLATIONS.

USE #0 TRACER WIRE WITH ALL BORES LONGER THAN 300'.

USE #0 TRACER WIRE AS REQUIRED FOR LARGE DIAMETER MAINS AND OTHER EXTRAORDINARY SITUATIONS AND COMPLEX BORES.

SPECTATOR APPROVAL REQUIRED FOR ALL TAPPING OPERATIONS.

TEST COVER UNLESS OTHERWISE NOTED.

DESIGNER DAN COOK @ 712-975-5444 OR FAX PRIOR TO CONSTRUCTION.

USE GAUGES TO MONITOR FIELD VERIFY EXISTING FEEDS & MAINS.

4" Extension for Katy Reserve

PURPOSE: SERVE AS BACK FEED FOR
 W DEVELOPMENT IN KATY.
 BEND COUNTY, TX.

DESIGNER: Sam Cook
 PHONE#: 713-207-5644
 DRAWN BY: Rudy Dertel
 DESIGN DATE: 5/20/2013

ESTIMATED COST:
 CONTRIBUTION:
 DATE NEEDED:
 RECOMMENDED BY:
 DATE:

APPROVED BY Kate Porter
 DATE 06/03/2013

SCALE: 1" = 100'
SHEET 1 OF 1

